

The manufacturer is awarded the following type test approval mark in virtue of a component test report:

Category type test approval mark:

safety valve

Technical inspection and surveillance organisation and test report:

TÜV Rheinland Industrie Service GmbH dated 2025-04-30

Manufacturer/Distributor:

WITT-Gasetechnik GmbH & Co KG  
Salinger Feld 4-8  
58454 Witten  
GERMANY

Type test approval mark:

TÜV . SV . 25 - 1215 . d<sub>0</sub> . D/G . α<sub>w</sub> . p  
and  
TÜV . SV . 25 - 1215 . d<sub>0</sub> . S/G . α<sub>w</sub> . p

Design:

direct-acting safety valve, spring-loaded

Type:

Ultravent 6  
and  
Ultravent 15

The award is made pursuant to:

- TÜV-Verband-Merkblatt Sicherheitsventil 100, edition 2022-12-14, in conjunction with TÜV-Verband Technical Leaflet General 002, edition 2022-09-20
- essential safety requirements laid down in Directive 2014/68/EU of 15 May 2014 (Pressure Equipment Directive)
- DIN EN ISO 4126-1:2016-12 + A2:2019-08
- DIN EN ISO 4126-7:2016-12
- AD 2000-Merkblatt A 4, edition 2015-11
- AD 2000-Merkblatt A 2, section 12.4 Safety valves for clean gases, edition 2020-01

Valid until:

2030-03-31

The award may be revoked. The previous certificate is replaced herewith.

Note: The manufacturer or importer must task the authorised inspector with conducting a yearly random check of components from the production line to establish their conformity with the approved type.

TÜV-Verband e. V.  
Friedrichstraße 136  
10117 Berlin

phone: +49 30 760095-400  
e-mail: bauteile@tuev-verband.de

---

Industry and plant engineering division

[www.tuev-verband.de/en](http://www.tuev-verband.de/en)